

Riley County Environmental Health
 110 Courthouse Plaza
 Manhattan, KS 66502
 (785) 537-6332



Date: 7/23/2018
Number of Pupils: 62

e-mail: BBURTON@usd384.org

ANNUAL SCHOOL ENVIRONMENTAL / SANITATION INSPECTION REPORT

School Name: Randolph Middle School	Address: #1 Ram Way
Inspected by: Perry Piper, EHS	
Accompanied by: Bill Heinen, Custodian	

EXTERIORS:	COMPLIANCE STATUS:	
	YES	NO
01 Exterior areas & surfaces: clean, good repair, debris, graded, no pooling water, illuminated	X	
02 Exterior structures: good repair, clean	X	
03 Playgrounds: equipment clean, good repair, ground cover (6"), storage, lighting		X
04 Refuse Containers: area clean, pests, odors, capacity, number, frequency, lids, solid surfaces	X	
*05 Outdoor vector control: harborage conditions; Exterior doors: tight fitting, good repair Windows/doors that open for ventilation: screening (#16 mesh), tight fitting, good repair	X	
06 Exterior Storage: machinery, maintenance items	X	

INSECT & RODENT CONTROL:

*07 No Presence of insects/rodents	X	
------------------------------------	---	--

ELECTRICAL SYSTEMS/LIGHTING:

*08 Installed, maintained according to code: ground - fault circuit interrupters within 5 ft of water source, switch outlet covered, breaker boxes: protected, good condition, wire splices covered, bare/frayed wiring: prohibited, 3 prong outlets grounded	X	
*09 Emergency lighting: adequate, good condition	X	
10 Lighting: adequate (≥ 30 FC classroom), (>100 FC lab or shop), shielding present, light bulbs/fixtures	X	

PLUMBING/WATER/SEWAGE:

11 Installed, maintained according to code	X	
*12 Backflow, cross-connection: present, tested annually	NA	
*13 Source: safe, capacity, hot and cold water under pressure, temperature	X	
*14 Sewage and waste water disposal	X	
15 Boiler inspection current	NA	

BATHROOMS:

16 Walls, ceiling, vents, floor: clean, good repair	X	
17 Hand sink: adequate, clean, good repair	X	
*18 Toilet bowl, seat: clean, sanitized, good repair (1:50 toilets & 1:35 urinals boys) (1:35 toilets girls)	X	
19 Soap, towels, toilet tissue, toiletry items: provided, replenished as necessary	X	
*20 Showers: clean, sanitized, good repair	X	

TOXIC ITEMS:

*21 Properly used, stored, labeled	X	
------------------------------------	---	--

PUBLIC INDOOR AREAS:

22 Temperatures regulated (68 F to 74 F Winter), (74 F to 89 F Summer)	X	
23 Structural Integrity; good repair, designed, disaster remediation	X	
24 Ceilings & Floors: good repair, designed, clean	X	

Additional Comments: School was being remodeled at the time of inspection.

3 The bottom board/seat on the top of the slide was cracked in half and needs replaced.

Room 102 81FC and Room 105 106.2FC.

Showers are not used, students have PE at high school as per Mr. Heinen.

Perry Piper

From: Perry Piper
Sent: Monday, July 23, 2018 3:37 PM
To: 'BBurton@USD384.org'
Cc: 'BBrenner@usd384.org'; Monty Wedel; Jennifer Green
Subject: USD 384 School Inspections

Good afternoon Mr. Burton,

I am the Environmental Health Specialist for Riley County and per Kansas Statutes Annotated (KSA) 65-202 I stopped by Randolph Middle School and Blue Valley High School today to conduct the annual school inspections. I interviewed Bill Heinen, Custodian at the middle school and Becky Brenner and Jim Nelson at the high school.

I understand the schools are going through a remodel process currently and I took that into consideration when I did the inspections. However, I did identify the following deficiencies that need your attention:

Randolph Middle School: The board/bottom seat on the top of the slide on playground is broken and needs replaced. I showed Mr. Heinen the board and he is aware of it.

Blue Valley High School:

- 1) The east handwashing sink hot water in the boys bathroom has a pencil tip stream - when turned on. There is not enough pressure for students to adequately wash their hands with hot water. Ms. Brenner and Mr. Nelson were made aware of it.

- 2) The electrical faceplates on missing on the 3-prong outlets on the east side wall of room 106 and the west side wall on room 105. I showed Mr. Nelson the missing electrical covers and he is aware of them.

Please send me photos of the completed repairs no later than **August 6, 2018**.

If you have any questions please call me.
Thank you,

Perry Piper

Environmental Health Specialist
Riley County, Planning & Development
110 Courthouse Plaza
Manhattan, Kansas 66502
785-537-6332



ANNUAL SCHOOL ENVIRONMENTAL / SANITATION INSPECTION REPORT

School Name: Blue Valley High School	Address: #2 Ram Way
Inspected by: Perry Piper, EHS	
Accompanied by: Becky Brenner and Jim Nelson	

EXTERIORS:	COMPLIANCE STATUS:	
	YES	NO
01 Exterior areas & surfaces: clean, good repair, debris, graded, no pooling water, illuminated	X	
02 Exterior structures: good repair, clean	X	
03 Playgrounds: equipment clean, good repair, ground cover (6"), storage, lighting	NA	
04 Refuse Containers: area clean, pests, odors, capacity, number, frequency, lids, solid surfaces	X	
*05 Outdoor vector control: harborage conditions; Exterior doors: tight fitting, good repair Windows/doors that open for ventilation: screening (#16 mesh), tight fitting, good repair	X	
06 Exterior Storage: machinery, maintenance items	X	

INSECT & RODENT CONTROL:	YES	NO
*07 No Presence of insects/rodents	X	

ELECTRICAL SYSTEMS/LIGHTING:	YES	NO
*08 Installed, maintained according to code: ground - fault circuit interrupters within 5 ft of water source, switch outlet covered, breaker boxes: protected, good condition, wire splices covered, bare/frayed wiring: prohibited, 3 prong outlets grounded		X
*09 Emergency lighting: adequate, good condition	X	
10 Lighting: adequate (≥ 30 FC classroom), (>100 FC lab or shop),	X	

PLUMBING/WATER/SEWAGE	YES	NO
11 Installed, maintained according to code	X	
*12 Backflow, cross-connection: present, tested annually	NA	
*13 Source: safe, capacity, hot and cold water under pressure, temperature		X
*14 Sewage and waste water disposal	X	
15 Boiler inspection current	NA	

BATHROOMS:	YES	NO
16 Walls, ceiling, vents, floor: clean, good repair	X	
17 Hand sink: adequate, clean, good repair	X	
*18 Toilet bowl, seat: clean, sanitized, good repair (1:50 toilets & 1:35 urinals boys) (1:35 toilets girls)	X	
19 Soap, towels, toilet tissue, toiletry items: provided, replenished as necessary	X	
*20 Showers: clean, sanitized, good repair	X	

TOXIC ITEMS:	YES	NO
*21 Properly used, stored, labeled	X	

PUBLIC INDOOR AREAS:	YES	NO
22 Temperatures regulated (68 F to 74 F Winter), (74 F to 89 F Summer)	X	
23 Structural Integrity; good repair, designed, disaster remediation	X	
24 Ceilings & Floors: good repair, designed, clean	X	

Additional Comments: School in process of remodeling at time of inspection.

*5 The 3-prong electrical outlets on the east wall of room 106 and the 3-prong electrical outlets on the west wall of room 105 were not covered.

*13 The east handwashing sink in the boys bathroom did not have adequate pressure on the hot water side for handwashing.

Perry Piper

From: Perry Piper
Sent: Monday, July 23, 2018 3:37 PM
To: 'BBurton@USD384.org'
Cc: 'BBrenner@usd384.org'; Monty Wedel; Jennifer Green
Subject: USD 384 School Inspections

Good afternoon Mr. Burton,

I am the Environmental Health Specialist for Riley County and per Kansas Statutes Annotated (KSA) 65-202 I stopped by Randolph Middle School and Blue Valley High School today to conduct the annual school inspections. I interviewed Bill Heinen, Custodian at the middle school and Becky Brenner and Jim Nelson at the high school.

I understand the schools are going through a remodel process currently and I took that into consideration when I did the inspections. However, I did identify the following deficiencies that need your attention:

Randolph Middle School: The board/bottom seat on the top of the slide on playground is broken and needs replaced. I showed Mr. Heinen the board and he is aware of it.

Blue Valley High School:

- 1) The east handwashing sink hot water in the boys bathroom has a pencil tip stream - when turned on. There is not enough pressure for students to adequately wash their hands with hot water. Ms. Brenner and Mr. Nelson were made aware of it.

- 2) The electrical faceplates on missing on the 3-prong outlets on the east side wall of room 106 and the west side wall on room 105. I showed Mr. Nelson the missing electrical covers and he is aware of them.

Please send me photos of the completed repairs **no later than August 6, 2018.**

If you have any questions please call me.
Thank you,

Perry Piper

Environmental Health Specialist
Riley County, Planning & Development
110 Courthouse Plaza
Manhattan, Kansas 66502
785-537-6332